

BUILDING SAFETY CERTIFICATE

No. 125

Dated : 11/07/2023

Certified that the existing building Sri Veerendra Patil Public School Chincholi Town in Chincholi Taliuka, Dist : Kalaburagi. DISE Coad 29040318501 & CBSE AFF No. 830248 (Name of the building or premises) at Chincholi Town in Chincholi Taliuka, Dist : Kalaburagi. (address) Comprised of Block 1 to 4 basement(s), 1st and 2nd (upper floor) Owned by Sri Veerendra Patil Education Trust Chincholi (name of the Institution) have complied with the Building safety requirements in accordance with National Building cod Rules, and verified by the officers concerned of Assistant executive engineer Karnataka Public Work Department (Name of Department/ Govt) on Date 11.07.2023 (Date of inspection) in the presence of Public Work Department Sub-Division Chincholi (name and addresses of the his representative) and that the building/ premises is fit for occupancy upto classes Ist to XIIth with effect from July- 2023 for the period of 5 years in accordance with rule and subject to compliance of the specific conditions as appended.

1. The stability of structure should be examined also reference to location attitude intensity of wind exposure of flood etc.
2. Any additional observation if deemed necessary for the certificate may be furnished Separately with the certificate.

Issued onatby

Name of the Officer : Sri Vishwanath Sajjanshetty AEE PWD Sub Division Chincholi

Designation : Assistant executive engineer

Name & Address of Department : Public Work Department Sub Division Chincholi Dist Kalaburgi



ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು

ದೋಣೀಪಯೋಗಿ ಇಲಾಖೆ ಉಪ-ವಿಭಾಗ

ಚಿಂಚೋಲಿ



PRINCIPAL

Sri Veerendra Patil Public School

CHINCHOLI

DISE CODE - 29040318501

CBSE AFF No. 830248

Vice President

Sri Veerendra Patil Education Trust (R.)

Chincholi, Dist-Kalaburgi

self attested



R K CONSULTANTS

Er. Khaja Pasha

BE Civil

N.D.T REPORTS

REBOUND HAMMER TEST RESULTS

1) Name of the Project:- Sri Veerendra Patil Public School Chincholi Tq.Chincholi

2) Name of Client :-

Sl No	Structural member Identification		Rebound Hammer Number			Avg Rebound Hammer Number	Cube Strength in N/mm ²
1	Slab		26	32	20	26	22
2			30	30	24	28	26
3			34	30	26	30	28
4			26	24	30	26	22
5			32	30	28	30	28
6			28	30	26	28	26



Vice President
Sri Veerendra Patil Education Trust (R)
Chincholi, Dist-Kaiburgi

Yours faithfully

(Er. Khaja Pasha)

Er. Khaja Pasha

(BE Civil & PWD Contractor)

Sandar Complex, Basaveshwara Circle
Sulepeth 585324, M-9880008353

PRINCIPAL
Sri Veerendra Patil Public Sch
CHINCHOLI

DISE CODE - 29040318501
CBSF AFF No 830248

self attested

R K CONSULTANTS SULEPETH